



Job Address: _____ **Des Moines, IA**

CERTIFICATION

I hereby certify that the hydrostatic test described below was witnessed by me or a designate under my personal supervision and that I am a duly registered professional engineer under the laws of the State of Iowa.

“NFPA 24

10.10.2.2 Hydrostatic Test

10.10.2.2.1 All piping and attached appurtenances subjected to system working pressure shall be hydrostatically tested at 200 psi (13.8 bar) or 50 psi (3.5 bar) in excess of the system working pressure, whichever is greater, and shall maintain that pressure without loss for 2 hours.”*

DESCRIPTION: (Portion of Systems Tested): _____

This test was successful within the limits of section NFPA 24-10.10.2.2.1

Test date: _____

Signature: _____

Address: _____

Iowa Registration No. _____